

GMS Thermal Products Ltd

Calorifiers, Heat Exchangers, Pressurisation Units

Vale Industrial Estate, Dukinfield, Cheshire SK16 4JA

Tel: 0161 344 1996 Fax: 0161 344 1995 E-mail: sales@gmsthermal.co.uk

Instructions for changing Set Point Temperature on Carel Controller

With power on:

Press SEL

Display changes to set point value

Use UP or DOWN arrows to change value

Press SEL to confirm value

Unit will now work at new set point.
